

SEATTLE / KING COUNTY PUBLIC HEALTH
Community Environmental Health
Plumbing / Gas Piping Inspections

**DECISIONS / INTERPRETATIONS
of the Chief Plumbing Inspector**

Date: June 15, 2004

Decision No. 04-003


Subject: Permit Requirements for Espresso Stands

Code / Section: 2003 UPC Section 103.0

Decision. Espresso stands which are constructed on-site shall require a plumbing permit. This shall apply to such stands where an approved potable water source other than from the water purveyor (such as bottled water systems) is provided and/or the drain system is not directly connected to the side sewer. The potable water source and the method of drainage disposal shall be acceptable to the food program of the Environmental Health division.

Background. Espresso stands that are constructed on-site will often involve the installation of water piping or tubing, drainage materials and fixtures, and water heating equipment. Such equipment must meet minimum code requirements, such as water distribution materials approved for potable water, fixture and drainage connections, and safety devices for water heating equipment.

Effective Date: June 16, 2004



Dave W Cantrell
Chief Plumbing Inspector

Apply's to "LIMITED"
FOOD SERVICE KIOSK" IN
ACCORDANCE WITH
KC CODE 5.37